

**Moriches Annex**  
For The  
**Mastics Moriches Shirley Community Library**

**HVAC**

H2M Architects and Engineers  
Sandpebble – Project Manager

August 27, 2021

**Contract #15.100 Addendum #1:**

*This Addendum shall supersede the original plans or specifications. All other conditions shall remain unchanged. The following changes shall be included within bids.*

**CHANGES TO THE DRAWINGS:**

**NONE**

**RFIs**

1. **QUESTION: Do the dashed lines on the drawing M100 indicate under floor zoning?**

**ANSWER: No, there is not under floor zoning**

2. **QUESTION: Can the bid due date be extended?**

**ANSWER: Yes, the bid due date will be extended to September 16<sup>th</sup>, 2021**

3. **QUESTION: In regard to the packaged unit alternate: Will the duct risers be on the inside or the outside of the building?**

**ANSWER: Inside**

4. **QUESTION: Is the raised access floor rated required a fire smoke damper as duct work passes through it?**

**ANSWER: No, there is no rating at the RAF level**

**OTHER BIDDING CLARIFICATIONS:**

- **The Bid due date has been extended. Sealed Bids are now due by 12pm Thursday September 16, 2021**
- **The Bid Opening will be at 1pm September 16, 2021 and will be read aloud via Zoom Conference call. Each Bidder will receive a link and password to the email provided on the Bidder Registration Card the morning of the 16<sup>th</sup>.**

**CHANGES TO BID FORM:**

**NONE**

Receipt and inclusion of all information provided in this **Contract #15.100 - Addendum #1** to be noted in the Addendum section of the **Bid Form** to be submitted per the Notice to Bidders and Instructions to Bidders provided in the bid package.

Should you have any questions or concerns please contact Ashley Lester of Sandpebble @ 631-287-6000, [ashley1@sandpebble.com](mailto:ashley1@sandpebble.com) as soon as possible.